



CLASS "C" CONCRETE

NOTES:

1. PLACE STANDARD 4" CURB DRAIN STUBS 30" BELOW THE TOP OF THE CURB OR AS DIRECTED.
2. INSTALL STANDARD STEPS PER AA-S119.
3. PRE-CAST WALLS SHALL HAVE A 5" MIN. THICKNESS & BE SUFFICIENTLY REINFORCED TO PERMIT SHIPPING & HANDLING WITHOUT DAMAGE.
4. MANHOLE SHALL BE IN ACCORDANCE WITH ASTM C478.

CITY OF COLUMBUS, OHIO
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF SEWERAGE & DRAINAGE

John J. Newsome

SSES MANAGER

CURB INLET MANHOLE

STANDARD DRAWING
 AA-S121

REVISED 7/9/12

PAGE

1
 1