



NOTES:

1. Vertical Bends Shall Be 11 1/4", 22 1/2" or 45"
2. Where "D" is 18" or Less, a Mechanical Joint Ductile Iron Offset may be used in lieu of the two Vertical Bends and the Inclined Nipple, as Approved by the Engineer.
3. Fire Hydrants shall be set a minimum of 6' from Residential Driveway Openings, and 10' from Commercial Driveway Openings.
4. All Bends are to be Included in the Cost of Item 801.
5. No Hydrant Extensions Will be Permitted without Prior Approval from DOW.
6. Wedge Type Bell Restraint Harness to be used if Joint is needed in Hydrant Lead.

CITY OF COLUMBUS
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF WATER

APPROVED:

*Bill G...
ADMINISTRATOR*

*9/21/22
DATE*

STANDARD DETAIL
TYPICAL HYDRANT SETTING
(TO ELIMINATE EXCESSIVE BURY)

