

I. MATERIALS

A. THE DUPLEX ALUMINUM SELF-SUPPORTING CABLE SHALL CONSIST OF 1-#6/7 STRAND ALUMINUM INSULATED CONDUCTOR AND 1-#6,6/1 ACSR BARE NEUTRAL. THE #6 AWG, 7 POLYETHYLENE INSULATION RATED AT 600 VOLT. THE ACSR #6 AWG, 6/1 STRAND CONDUCTOR SHALL BE BARE.

THE INSULATION SHALL BE CHEMICALLY CROSS-LINKED, LIGHT AND HEAT RESISTANT, THERMOSETTING POLYETHYLENE AND COMPLY WITH THE LATEST ASA SPECIFICATION NO. C8.35, AND ICEA S-19-81.

THE ALUMINUM WIRE SHALL COMPLY WITH THE LATEST APPLICABLE ASTM B230/B230M, B231/B231M, B-232/B232M, B399/B399M, AND B786/786M SPECIFICATIONS FOR ALUMINUM WIRE AND STRANDED ELECTRICAL CONDUCTORS.

- B. THE SECONDARY RACKS SHALL BE HEAVY DUTY, HOT DIPPED GALVANIZED STEEL, WITH SINGLE 3" SPOOL INSULATOR PORCELAIN PRODUCTS #5101 OR APPROVED EQUAL.
- C. THE SPLICES SHALL BE ALUMINUM COMPRESSION TYPE, EQUAL TO HUBBELL / BURNDY HYLINK PRODUCTS.
- D. THE TIE WIRES SHALL BE #6 ALUMINUM.
- E. THE THROUGH BOLTS, NUTS, AND WASHERS SHALL BE HOT DIPPED GALVANIZED, 5/8" DIAMETER
- F. THE INSULATING PADS SHALL BE APPROXIMATELY 3-1/4" X 4-1/2" X 0.125" SCOTCH #2200 OR APPROVED EQUAL.

II. INSTALLATION

- A. THE OVERHEAD CIRCUIT SHALL BE INSTALLED IN THE LOCATIONS SHOWN ON THE CONTRACT DRAWINGS AND INDICATED IN THE FIELD BY THE ENGINEER.
- B. NO MID-SPAN SPLICING WILL BE PERMITTED. SPLICING IS ONLY PERMITTED AT CONDUCTOR DEAD ENDS.

C. THE CONDUCTOR SHALL BE STRUNG AND SAGGED IN ACCORDANCE WITH THE NATIONAL ELECTRIC SAFETY CODE, AND MANUFACTURER PROVIDED SAG AND TENSION CHARTS.

III. BASIS OF PAYMENT

ITEM	UNIT	DESCRIPTION
MIS-402	CIRCUIT FOOT	OVERHEAD CIRCUIT, 2 WIRE-#6 DUPLEX

MIS-402	DEPARTMENT OF PUBLIC UTILITIES - DIVISION OF POWER CITY OF COLUMBUS, OHIO		
	OVERHEAD CIRCUIT, 2 WIRE- #6 DUPLEX		
	DRAWN BY: SAW	DATE: 1/1/24	
	SCALE: NONE	SHEET: 1 OF 1	402